

Consumer Confidence Report

Annual Drinking Water Quality Report

CENTRALIA
IL1214220

Annual Water Quality Report for the period of January 1 to December 31, 2020
This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by CENTRALIA is Surface Water

For more information regarding this report contact:

Name Dean Swingle
Phone 618-533-7623

Note: Informa contains information may require a subscription fee and may be available on a fee basis. Informa is available on a fee basis.

Source of Drinking Water
The source of drinking water (both tap water and bottled water) include rivers, lakes, streams, reservoirs, and other surface water sources. Surface water is collected over the surface of the land or through the ground. It is collected from various sources, including rivers, lakes, streams, and other surface water sources. It is then treated to remove any contaminants that may be present in the source water.
Contaminants that may be present in source water include:
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential use.
- Organic chemical contaminants, including volatile organic compounds, which may come from solvents, gasoline, and other petroleum products.
- Inorganic chemical contaminants, including nitrate, which may come from fertilizers, industrial processes, and other sources.
- Radon, a naturally occurring radioactive gas that can be found in some groundwater sources.
- Disinfection byproducts, which are formed when disinfectants are used to kill bacteria and other microorganisms in the water.
- Other contaminants, such as pharmaceuticals, personal care products, and industrial chemicals.

Drinking water, including bottled water, may sometimes be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water is unsafe to drink. Some contaminants, such as disinfection byproducts, are known to be present in drinking water and are regulated by the EPA. The EPA's Safe Drinking Water Act (SDWA) requires public water systems to monitor for and report on certain contaminants in their drinking water. The EPA also sets maximum contaminant levels (MCLs) for certain contaminants in drinking water. The MCLs are the maximum level of a contaminant that is allowed in drinking water. The MCLs are based on the best available science and are designed to protect public health.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The regulations establish MCLs for certain contaminants in drinking water. The MCLs are the maximum level of a contaminant that is allowed in drinking water. The MCLs are based on the best available science and are designed to protect public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Infants and young children, pregnant women, and the elderly are particularly at risk. People with certain medical conditions, such as kidney disease, may also be more vulnerable to contaminants in drinking water. People who are taking certain medications may also be more vulnerable to contaminants in drinking water. If you are pregnant, nursing, or preparing food for infants and young children, you should take special care when drinking water. You should also take special care when preparing food for infants and young children. You should also take special care when drinking water. You should also take special care when preparing food for infants and young children.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is most likely to come from old service lines and home plumbing. The EPA's Lead Action Plan requires public water systems to take steps to reduce lead in drinking water. The EPA also requires public water systems to monitor for lead in drinking water. The EPA also requires public water systems to report on lead in drinking water. The EPA also requires public water systems to take steps to reduce lead in drinking water. The EPA also requires public water systems to monitor for lead in drinking water. The EPA also requires public water systems to report on lead in drinking water. The EPA also requires public water systems to take steps to reduce lead in drinking water.

Source Water Information

Source Water Name	Type of Water	Report Status	Location
INTAKE (01293) CREEKLYE LAKE	SW		
INTAKE (01951) LAKE CREEKLYE NEAR	SW		

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 618-533-7681. To view a summary version of the completed Source Water Assessment, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wf/swap-fact-sheets.pl>.

Source of Water: CENTRAL Illinois EPA considers all surface water sources of public water supply to be susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection. Primary sources of pollution in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion.

2020 Regulated Contaminants Detected

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. coli Maximum Contaminant Level	Total No. of Positive E. coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 Positive monthly sample.	1		0	N	Naturally present in the environment.

Lead and Copper

Definitions:
Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. Also allow for a margin of safety.
Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	08/24/2018	1.3	1.3	0.17	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	08/24/2018	0	15	1.1	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

AVG:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Water Quality Test Results

Maximum residual disinfectant level or MDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
mgem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chloramines	12/31/2020	3.1	3 - 3.5	MCLG = 4	MCL = 4	ppm	N	Water additive used to control microbes.
Halocetic Acids (HAA5)	2020	25	10.83 - 30.8	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (THM)	2020	56	32.5 - 72.2	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2020	0.053	0.053 - 0.053	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2020	0.8	0.763 - 0.763	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2020	2	2.1 - 2.1	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	2020	18	18 - 18			ppm	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2020	0.82	0 - 0.82	3	3	ppb	N	Runoff from herbicide used on row crops.
Simazine	2020	0.67	0 - 0.67	4	4	ppb	N	Herbicide runoff.

Turbidity

Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
-----------------------------	----------------	-----------	--------------------------------

MAXT

Highest single measurement	1 NTU	0.23 NTU	N	Soil runoff.
Lowest monthly & meeting limit	0.3 NTU	100%	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The Percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.